

Coast Guard, DHS

§ 95.17-5

(i) The pressure must be 150 pounds per square inch; and

(ii) Distribution piping must be capped within the protected space at the first joint upstream of the nozzles.

(3) Pneumatic actuation piping must be tested as described in paragraph (a)(1) of this section.

(b) *Inert gas systems.* A pressure test using air or inert gas must be conducted on each inert gas system's piping on completion of piping installation and before extinguishing agent cylinders are connected.

(1) Except as otherwise specified in this section:

(i) Piping from the cylinders to the stop valves or selector valves must be subjected to a pressure of 1,000 pounds per square inch (psi) at 70 °Fahrenheit; and

(ii) The leakage during a 2-minute period must not exceed a pressure drop of 100 psi.

(2) Individual branch lines to a protected space must be tested as described in paragraph (b)(1) of this section, except that:

(i) The pressure must be 600 psi; and

(ii) Distribution piping must be capped within the protected space at the first joint upstream of the nozzles.

(3) Pneumatic actuation piping must be tested as described in paragraph (b)(1) of this section.

(c) *Small independent systems.* In lieu of test requirements in paragraphs (a) or (b) of this section, a small independent halocarbon or inert gas system, like those found in emergency generator rooms and paint lockers, may be tested by blowing out the piping with air pressure of at least 100 psi, if:

(1) There are no valves in the system discharge piping; and

(2) There is not more than one change in direction between the agent container and the discharge nozzle.

§ 95.16-90 Installations contracted for prior to July 9, 2012.

Installations contracted for prior to July 9, 2012, must meet the requirements of this subpart unless previously approved existing arrangements, materials, and facilities are:

(a) Maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection; and

(b) Subjected to no more than minor repairs or alterations implemented to the same standards as the original installation.

Subpart 95.17—Foam Extinguishing Systems, Details

§ 95.17-1 Application.

(a) Where a foam extinguishing system is installed, the provisions of this subpart, with the exception of § 95.17-90, shall apply to all installations contracted for on or after November 19, 1952. Installations contracted for prior to November 19, 1952, shall meet the requirements of § 95.17-90.

§ 95.17-5 Quantity of foam required.

(a) *Area protected.* (1) For machinery and similar spaces, the system shall be so designed and arranged as to spread a blanket of foam over the entire tank top or bilge of the space protected. The arrangement of piping shall be such as to give a uniform distribution over the entire area protected.

(2) Where an installation is made to protect an oil fired boiler installation on a flat which is open to or can drain to the lower engine room or other space, both the flat and the lower space shall be protected simultaneously. The flat shall be fitted with suitable coamings on all openings other than deck drains to properly restrain the oil and foam at that level. Other installations of a similar nature will be considered in a like manner.

(3) Where a system is installed to protect a tank, it shall be so designed and arranged as to spread a blanket of foam over the entire liquid surface of the tank within the range of usual trim. The arrangement of piping shall be such as to give a uniform distribution over the entire area protected.

(b) *Rate of application.* (1) For spaces other than tanks, the rate of discharge to foam outlets protecting the hazard shall be at least as set forth in this paragraph.

(i) For chemical foam systems with stored "A" and "B" solutions, a total of at least 1.6 gallons per minute of the

§95.17-10

two solutions shall be discharged for each 10 square feet of area protected.

(ii) For other types of foam systems, the water rate to the dry powder generators or air foam production equipment shall be at least 1.6 gallons per minute for each 10 square feet of area protected.

(2) For tanks, the rate of discharge to foam outlets protecting the hazard shall be as set forth in paragraph (b)(1) of this section, except that the value of 1 gallon per minute shall be substituted in both cases for the value of 1.6 gallons per minute.

(c) *Supply of foam producing material.*

(1) There shall be provided a quantity of foam producing material sufficient to operate the equipment at the discharge rate specified in paragraph (b) of this section for a period of at least 3 minutes for spaces other than tanks, and for at least 5 minutes for tanks.

(d) *Separate supply of foam agent.* A separate supply of foam agent need not be provided for each space protected. The total available supply shall be at least sufficient for the space requiring the greatest amount.

(e) *Water supply for required pumps.* Where pumps are required, the water supply shall be from outside the space protected and shall in no way be dependent upon power from the space protected.

§95.17-10 Controls.

(a) The foam agent, its container, and all controls and valves for the operation of the system shall be of an approved type.

(b) The foam agent container and all controls and valves for the operation of the system shall be outside the space protected and shall not be located in such space as might be cut off or made inaccessible in the event of fire in any of the spaces protected. The control space shall be as convenient as practicable to one of the main escapes from the spaces protected, and shall be marked as required by §97.37-13 of this subchapter. Where pumps are required, it shall not be necessary that they be started from the control space.

(c) Complete, but simple instructions for the operation of the system shall be located in a conspicuous place at or near the controls.

46 CFR Ch. I (10-1-12 Edition)

(d) The valves to the various spaces served shall be marked as required by §97.37-10 of this subchapter.

§95.17-15 Piping.

(a) All piping, valves, and fittings shall meet the applicable requirements of Subchapter F (Marine Engineering) of this chapter.

(b) All piping, valves, and fittings of ferrous materials shall be protected inside and outside against corrosion unless specifically approved otherwise by the Commandant.

(c) All piping, valves, and fittings shall be securely supported, and where necessary, protected against injury.

(d) Drains and dirt traps shall be fitted where necessary to prevent the accumulation of dirt or moisture.

(e) Piping shall be used for no other purpose.

§95.17-20 Discharge outlets.

(a) Discharge outlets shall be of an approved type.

§95.17-25 Additional protection required.

(a) In order that any residual fires above the floor plates may be extinguished when a foam system is installed for the protection of spaces other than tanks, at least 2 fire hydrants, in addition to those required for the machinery space by Subpart 95.10, shall be installed outside of the machinery space entrance. Such hydrants shall be fitted with sufficient hose so that any part of the machinery space may be reached with at least 2 streams of water, and each hose shall be equipped with an approved combination nozzle, applicator, and self-cleaning strainer as described in §95.10-10(i)(3).

§95.17-90 Installations contracted for prior to November 19, 1952.

(a) Installations contracted for prior to November 19, 1952, shall meet the following requirements:

(1) Existing arrangements, materials, and facilities previously approved shall be considered satisfactory so long as they meet the minimum requirements of this paragraph and they are maintained in good condition to the satisfaction of the Officer in Charge, Marine